



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE  
04333-0016

JOHN ELIAS BALDACCI  
GOVERNOR

DAVID A. COLI  
COMMISSIONER

May 23, 2003  
Subject: Minot-Auburn  
Project No. STP 9184(00)X  
PIN No. 9183.00  
**Bid Amendment No. 1**

Dear Sir/Ms.:

Please make the following changes to your Bid Package:

- 1.) In the Contract book please add the attached Special Provision Section 203, 'Excavation and Embankment (Dredge Materials)' 1 page dated, 9 May 2003.
- 2.) On Plan Sheet # 7 of 147, entitled "General Notes", Add the following as Note # 50 "Dredge Material (See MDOT Standard Specifications § 101.2) is regulated as a Special Waste. Fifty cubic yards or less of Dredge Material **Beneficially Used in the area adjacent to and draining into the dredged water body** is exempt from regulation. The Contractor shall ensure that Dredge Material is placed into the fill areas specified by MDOT. No more than the fifty cubic yards (38 cubic meters) of Dredge Material may be excavated without authorization from the Engineer. Any Dredge Material not Beneficial Used (excess Dredge Material) shall be disposed of at a landfill licensed by the Maine Department of Environmental Protection to accept Special Waste. The Contractor shall be responsible for making all necessary arrangements for dewatering and proper disposal of the Dredge Material, including any additional laboratory testing, in accordance with the landfill's license. The Contractor shall provide documentation to the Engineer that any such Dredge Material was disposed of as specified."



PRINTED ON RECYCLED PAPER

3.) The Department has received the following RFI's:

**Question.)** This job calls for a 1600 mm x 1220 mm box culvert. This translates to 5' 3" x 4', which we are unable to do. If either 5' x 4' or 6' x 4' would be acceptable, please let me know your preference.

**Response:** *MDOT will accept a 1525 mm x 1220 mm box. (5' x 4')*

Consider these changes and information prior to submitting your bid on May 28, 2003.

Sincerely

A handwritten signature in cursive script that reads "Bruce R. Carter".

Bruce R. Carter  
Contracts Engineer

MINOT-AUBURN-9183.00  
9 MAY 2003

SPECIAL PROVISION  
SECTION 203  
EXCAVATION AND EMBANKMENT  
(Dredge Materials)

**Description:** Dredge Material (See MDOT Standard Specifications § 101.2) is regulated as a Special Waste.

Fifty cubic yards or less of Dredge Material Beneficially Used in the area adjacent to and draining into the dredged water body or streambed is exempt from regulation.

CONSTRUCTION REQUIREMENTS

**Management and Disposal:** The contractor shall Beneficially Use all Dredge Material in the area adjacent to and draining into the dredged water body or streambed. No more than 38 cubic meters (50 cubic yards) of Dredge Material may be excavated without the authorization of the Engineer.

**Method of Measurement:** Dredge Material will be measured by the cubic meter of material removed.

**Basis of Payment:** Payment shall be full compensation for excavation, dewatering, managing, transporting, and placement. If the contract contains a Structural Earth Excavation Pay Item, Dredge Material Beneficially Used will be paid for at the contract unit price bid for Common Excavation.

<u>Pay Item</u>		<u>Pay Unit</u>
203.20	Common Excavation	cubic meter